



CHENNAI METTEX LAB PRIVATE LIMITED

Jothi Complex, 83, M.K.N. Road, Guindy, Chennai - 600 032.

TEST REPORT

Page No. 1 of 1

ISSUED TO : M/s.Anugraha Satellite Township,
Periyakaatupalayam, Madalampattu Village,
Cuddalore Taluk, Cuddalore Dist.

T.C Date : 09.06.2018

T.C No : CML/18-19/15908

Date Of Receipt : 05.06.2018

Commenced On : 05.06.2018

Completed On : 09.06.2018


Cust. Ref : SRF Dated: 05.06.18

Lab No : 1916214

Sample Description : STP Inlet Water.

Sl.No	Characteristics Test	Protocol	Results
1	pH at 25°C	IS 3025 Part 11-1983 (Reaff.2012)	7.52
2	Total Suspended Solids	IS 3025 Part 17-1984 (Reaff.2012)	126 mg/l
3	COD	IS 3025 Part 58 -2006(Reaff.2012)	150 mg/l
4	BOD @ 27°C for 3 Days	IS 3025 Part 44-1993 (Reaff.2014)	42 mg/l
5	Ammonical Nitrogen as N	IS:3025 Part 34-1988 (Reaff:2014)	20.02 mg/l
6	Total Nitrogen as N	IS:3025 Part 34-1988 (Reaff:2014)	22.0 mg/l
7	Faecal Coliforms	IS: 1622: 1981(Reaff:2009)	900 MPN/100ml

Note : BDL – Below Detection Limit, DL – Detection Limit, MPN: Most Probable Number.


G.S. RADHA
Technical Manager

End of Report



For Chennai Mettex Lab Private Limited


P. KAVITHA
Technical Manager

NOTE: Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders will be liable for legal action. Unless otherwise stated the submitted results in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only from the completion date of testing, except in case of regulatory samples, which will be retained for a specific period as per statutory requirement; while perishable & environmental testing related remnant samples will be discarded consequent upon completion of testing. Samples are not drawn by us unless otherwise stated. This document cannot be reproduced except in full, without prior written approval of the laboratory. This report is for the exclusive use of Chennai Mettex Lab's customer, and is provided in accordance with the agreement between Chennai Mettex Lab and its Customer. # Indicates not come under the scope of accreditation.



CHENNAI METTEX LAB PRIVATE LIMITED[®]

ORIGINAL FOR RECIPIENT

Jothi Complex, 83, M.K.N. Road, Guindy, Chennai - 600 032.

GSTIN : 33AADCC5319A2ZB - SAC Code : 998346 - Technical Testing & Analysis Services State : Tamilnadu, State Code :33
PAN : AADCC5319A PF A/c No: TBTAM0061790000 ESIC A/c. No. 51000866810000301
BANK DETAILS : IDBI BANK - OTA BRANCH - Chennai - 600016 Current A/c. No.: 904102000003698 IFSC : IBKL0000904 SWIFT - IBKL IN BB 005

TAX INVOICE

To: M/s. Anugraha Satellite Township, Periyakaatupalayam, Madalampattu Village, Cuddalore Taluk, Cuddalore Dist.		Bill No : 1819004649 Date : 09/06/2018		
GST No : NON GST		PAN No : N GST		State Code & Name : 33 - Tamil Nadu
Customer Reference : SRF Dated : 05.06.2018				
T.C. No : CML/18-19/15908,15909				
S.No	Particulars	Qty	Rate (per Sample)	Amount (Rs)
1	Analysis of STP Inlet & Outlet	2	2,300.00	4,600.00
			Sub Total	4,600.00
			CGST @ 9 %	414.00
			SGST @ 9 %	414.00
Rs. FIVE THOUSAND FOUR HUNDRED TWENTY-EIGHT ONLY			Total (Rounded Off)	5,428.00

For CHENNAI METTEX LAB PRIVATE LTD.,


Authorized Signatory